



BV LCIE  
CHINA  
Number

N° 2366AS05CIPN49824

## ATTESTATION of conformity with European Directives

*Product:* **MCB**  
*Reference* **GYM9H**  
*Issued to* **ZHEJIANG GEYA ELECTRICAL CO., LTD**  
*Address* **Wenzhou Bridge Industrial Zone, Beibaixiang Twon, Yueqing City,  
Zhejiang Province, China 325603**  
*Manufacturer* **ZHEJIANG GEYA ELECTRICAL CO., LTD**  
**Type C and B**  
**Ue:240/415V~ and 230/400V~ for 1P; 415V~ and 400V~ for 2P/3P/4P**  
**In=6; 10; 16; 20; 25; 32; 40; 50; 63A**  
**Ics=7500A or 6000A**  
**Icn=10000A or 6000A**  
*Technical characteristics* **50/60Hz**  
**Energy limit class: 3 (according to EN 60898-1)**  
**Grid distance: 50mm**  
**Ui=500V**  
**Uimp=4kV**  
**Screw diameter of terminal =5,0mm**

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

**Low Voltage Directive 2014/35/EU**

<i>Standards</i>	<i>Report number</i>	<i>Report date</i>
<b>EN 60898-1:2019</b>	<b>B220127</b>	<b>20/03/2023</b>

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product  
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

**Shanghai (P.R. China), May 18<sup>th</sup>, 2023.**

**Charlie CHEN**  
**Product Line Manager**



be reproduced, except in full, without the written approval of BV LCIE China.

Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA

必维欧亚电气技术咨询服务(上海)有  
限公司

Building 4, No. 518, Xin Zhuan Road,  
CaoHejing Songjiang High-Tech Park,  
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000  
Fax: +86 21 6195 7001  
Email: [contact@cn.bureauveritas.com](mailto:contact@cn.bureauveritas.com)