



**BUREAU
VERITAS**

ATTESTATION of conformity with UK legislation

BV LCIE CHINA Number N°2266AS10GYB47206
Product RCCB
Reference GYL9
Issued to ZHEJIANG GEYA ELECTRICAL CO., LTD.
Address WENZHOU BRIDGE INDUSTRIAL ZONE, BEIBAIXIANG TOWN
325603 YUEQING, ZHEJIANG - CHINA
Manufacturer ZHEJIANG GEYA ELECTRICAL CO., LTD.
Technical characteristics
1P+N and 3P+N(neutral on left)
230/240V(1P+N);400/415V(3P+N)
In=16A; 25A; 40A; 63A; 80A
Inc=IΔc=10000A
Im=IΔm=500A for 16A; 25A; 40A and 10In for 63A; 80A
IΔn=30mA; 100mA; 300mA
Grid distance = 50mm
Ui= 415V
Uimp=4kV
Material group=IIIa
Screw diameter=5,9mm
50/60Hz

The submitted sample of the above equipment has been tested for the below regulation(s):

- Electrical Equipment (Safety) Regulations 2016*

Standards	Report number	Report date
BS EN 61008-1:2012+A12:2017	GYB-ESH-P22061923	24/10/2022

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of conformity with the principle elements of the safety objectives covered by that standards

This verification does not imply assessment of the production of the product

The UKCA marking may be affixed on the product if all relevant UK legislations are fulfilled

Shanghai (P.R. China), October 24th, 2022

Charlie CHEN

Product Line Manager

**UK
CA**

This document shall not be reproduced, except in full, without the written approval of BV LCIE China. Information given in this document, are related to the tested specimen of the described electrical sample.