



BV LCIE
CHINA
Number

N°1666AS06GYB20893

ATTESTATION of conformity with European Directives

Product: **RCCB**
Reference **GYL8&GYL10**
Issued to **ZHEJIANG GEYA ELECTRICAL CO., LTD**
Address **WENZHOU BRIDGE INDUSTRIAL ZONE, BEIBAIXIANG TOWN,
YUEQING,ZHEJIANG, CHINA 325603**
Manufacturer **ZHEJIANG GEYA ELECTRICAL CO., LTD**
Technical characteristics **240V for 1P+N and 415V for 3P+N (Neutral on right)
Type AC and Type A (30mA;100mA;300mA) for 16A; 20A; 25A; 32A;
40A; 50A; 63A
In=16A; 20A; 25A; 32A; 40A; 50A; 63A
Inc = 6000A;IΔc = 6000A; 50Hz
IΔn = 30mA;100mA;300mA**

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

<i>Standards</i>	<i>Report number</i>	<i>Report date</i>
EN 61008-1:2012+A1:2014+A2:2014 EN 61008-2-1:1994 + A11:1998	B160001-00 to B160001-10	23/03/2016

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product.
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), June 17th, 2016.



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.